

C-32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/School/2022/ 504

Dated: 24/08/2022

To

The Principal,  
NDMC Primary Co-Ed School,  
Lal Kuan, Delhi- 06.

Sub: - Regarding issuance of "**Fire Safety Certificate**" from fire safety point of view in r/o  
**NDMC Primary Co-Ed School, Lal Kuan, Delhi- 06.**


Sir,

Please refer to your letter no. nil dated 27.07.2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school premises on 12.08.2022 to verify the fire safety arrangements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education. At the time of inspection Mr. Amilal Yadav (Chowkidar) was present and it was observed that the school building is comprised of ground plus two upper floors and have complied the shortcomings issued vide letter no. F.6/DFS/MS/School/2014/2316 dated 29.09.2014 except following which still exists:-

1. The school is not accessible to fire engines as approach road width is less than 06 meters.
2. Additional staircase having width of not less than 0.75 m is required.

In view of above, the fire safety certificate cannot be issued. You are suggested to rectify the above said shortcomings under the intimation to this department for further course of action. Running school without valid Fire Safety Certificate is at risk and liability of school management. Concerned authority may take action at their end.

Yours faithfully,

  
23/08/22  
(S.K. Dua)

Dy. Chief Fire Officer o/c  
Delhi Fire Service

23/8

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi