

c-56

~~del~~

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2022/9H/665

Dated: 08/08 /2022

To

The Manager,
New Hindustan International Dx. 2503,
Nalwa Street, Chuna Mandi,
Pahar Ganj, New Delhi.

Subject:- Regarding issuance of FSC in r/o M/s New Hindustan International Dx. 2503, Nalwa Street, Chuna Mandi, Pahar Ganj, New Delhi. ID No. 2022070414019 dated 05.07.22.

Sir,

This has a reference to online application ID No. 2022070414019 dated 05.07.22, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officers concerned department on 27/07/2022 in the presence of Manager and following shortcomings were observed:-

1. Fire check doors are not installed as per gazette notification 27.05.2019. .
2. Smoke management system not installed as per gazette notification 27.05.2019.
3. The building is comprised of ground and four upper floor where as 4th floor plan is not submitted.
4. The building plan does not have signature of owner /occupier himself.

In view of above, the Fire safety certificate cannot be issued. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,



(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Officer

Copy to :-

The Jt. Commissioner of police (Lic) Ist Floor , Defense colony police station , New Delhi