



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No. F6/DFS/MS/EH/2022/NDZ/509

Dated: 02/08/2022

To,

Mr. Mohd Furqan  
House No. 901, Gali No. 06,  
Chauhan Bangar, Jafrabad,  
Delhi-110053

Sub:- Regarding Issuance of Fire Safety Certificate in r/o M/s Pind Baluchi (Unit of Royal Cuisine) located 410, Karkardooma Village, Delhi- 110092.

Sir,

With reference to your online MHA application No. **2022052210903** dated 23/05/2022 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection the premises from fire safety point of view in presence of Ms. K.K. Jain, Manager on dated 25/06/2022. The eating house running at ground plus two upper floors of the building comprised of basement, ground plus four upper floors. Following shortcomings were observed during the time of inspection.

1. Fire Check door shall be required to be provided.
2. 02 doors of width 1.10 meter and 0.75 meter are provided against requirement of 02 doors of width 1.50 meter & 1.00 meter.
3. Down comer & First Aid Hose reels provided but not functional.
4. Jockey pump 180 lpm not provided.
5. Over Head Tank 5000 liter not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(S. K. DUA)

o/c Dy. Chief Fire Officer /  
(NDZ)

Copy to:-

The Joint Commissioner (Lic.)  
1<sup>st</sup> floor Police Station Defence Colony, New Delhi