



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2022 / 491

Dated: 23/8/22

To

The Principal (Morning/Evening shift),
Sarvodaya Co-Ed Vidyalaya (New SPS construction),
Hari Nagar, Ashram, New Delhi
School ID no. 1924043 & Building ID no. 19241639.

Sub:- Regarding issuance of Fire Safety Certificate in r/o **Sarvodaya Co-Ed Vidyalaya (New SPS construction) located at Hari Nagar, Ashram, New Delhi (Building ID no. 19241639).**

Sir,

With reference to your letter no. 54 (SPS School)/PWD Edu. Maint. Sub-Div/M-1-3/2021-22/181 dated 22.03.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 04.08.2022 in the presence of Mrs. Madhu Sachdeva (Principal) and it was observed that the school building is comprised of 02 blocks (ground + 03 upper floors each). During the inspection following shortcomings were observed:-

1. Fire extinguishers (24 nos.) found not provided.
2. First aid hose reels found non function.
3. Fire pump found non functional.
4. Exit sinages found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Gang)
Director

Delhi Fire Service

o/c 1878

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. Assistant Engineer (E), PWD Sub-Division M1-PWD, Hauz Khas, New Delhi-16.