



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आजादी का  
अमृत महोत्सव  
GMI

No. F6/DFS/MS/School/SZ/2022 / 492

Dated: 23/8/22

To

The Principal (Morning/Evening shift),  
Sarvodaya Kanya Vidyalaya (New SPS construction),  
New Friends Colony, New Delhi  
School ID no. 1925033 & Building ID no. 19251395

Sub:- Regarding issuance of Fire Safety Certificate in r/o **Sarvodaya Kanya Vidyalaya (New SPS construction) located at New Friends Colony, New Delhi (Building ID no. 19251395)**.


Sir,

With reference to your letter no. 54 (SPS School)/PWD Edu. Maint. Sub-Div/M-1-3/2021-22/183 dated 28.03.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.08.2022 in the presence of Mrs. Indira Sagar (HOS) and it was observed that the school building is comprised of 02 blocks (ground + 03 upper floors each). During the inspection following shortcomings were observed:-

1. Fire extinguishers (24 nos.) found not provided.
2. First aid hose reels found non function.
3. Fire pump found non functional.
4. Exit sinages found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Arul Garg)  
Director

Delhi Fire Service

etc 16/8

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. Assistant Engineer (E), PWD Sub-Division M1-PWD, Hauz Khas, New Delhi-16.