



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/11  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2022/ 500

Dated: 23/8/22

To

The Principal,  
SDMC Primary School,  
Krishna Market, G-block, Lajpat Nagar-I,  
New Delhi-24 (ID no. 1958025).

**Sub:-** Regarding renewal of Fire Safety Certificate in r/o **SDMC Primary School, Krishna Market, located at G-block, Lajpat Nagar-I, New Delhi-24 (ID no. 1958025).**

Sir,

With reference to your letter no. nil dated 06.04.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 17.06.2022 in the presence of teacher and it was observed that the building is comprised of ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. Hose reels found non functional.
2. Fire pump found non functional.
3. After the compliance of shortcomings mentioned above, MCD shall provide the 2<sup>nd</sup> staircase of 1.5 meters width as per requirement in UBBL 2016, within 01 year of renewal of Fire safety Certificate.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

o/c  
16/8

**Copy to:-**

1. The Directorate of Education, South DMC, 9<sup>th</sup> Floor, Dr. SPM Civic Centre, Minto Road, New Delhi-110002.