

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2022/ 647

Dated: 5/8 /2022

To

The Manager,
Star International Guest House,
8172, A.K. Road,
New Delhi.

Subject:- Regarding issuance of FSC in r/o Star International Guest House, located at 8172, A.K. Road, New Delhi. ID No. 2022070914297 dated 11.07.22.

Sir,

This has reference to on line ID No. 2022070914297 dated 11.07.22 on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 26.07.22 in presence of Manager and found following shortcomings:-

1. Hose reel provided but found nonfunctional.
2. Fire Pump found non functional
3. Smoke management system and CO type detectors are not provided as per gazette notification dated 27.05.2019.

In view of above, the Fire safety certificate cannot be issued. Therefore, you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,



(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

The Jt. Commissioner of police (Lic) Ist Floor , Defense colony police station , New Delhi