

e-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2022/SZ/ 519
To

Dated: 08/08/2022

The Dy. Health Officer, SDMC,
Public Health Department,
Aurobindo Marg, Green Park Zone,
Green Park, Delhi- 110016

Sub: Regarding issuance of FSC in r/o M/s UBER Lounge (A unit of Ms Silver Spoon entertainment Pvt Ltd.) M-42, Ground Floor, Greater Kailash- II Market, Delhi 110048

Sir,

This has reference to MHA Portal ID No. 2022061512823 dated 24/06/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department in the presence of Mr. Vishnu on 27/07/2022 to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are two Exit doors available having with width of 1.60 mtr & 1.30 mtr respectively. The second exit door is less than of 1.50m against the required width of 1.50 mtr.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to:-

1. M/s UBER (A unit of Ms Silver Spoon entertainment Pvt Ltd.) M-42, Ground Floor, Greater Kailash- II Market, Delhi 110048
2. The Addl. Commissioner of Police, Lic/Branch, 1st Floor, P.S Defence Colony, New Delhi 110049