

e 39

e 40

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 2022/ 675

Dated:-10/08/2022

To,

The Manager,
Unique International Guest House,
902, Gali Chandi Wali, Main Bazar,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Unique International Guest House, 902, Gali Chandi Wali, Main Bazar, Pahar Ganj, New Delhi. ID No. **2022070514026** dated **05.07.22**.

Sir,

This has reference to on line id no. **2022070514026** dated **05.07.22**, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 02/08/2022 in the presence of **Manager** and following shortcomings were observed: -

1. Smoke Management system is not provided as per Gazette Notification dated 27.05.2019.
2. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.
3. Fire Pump not in auto mode start provision.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully,



(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.