

C-2

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F-6/DPS MS/School/2022/

485

Dated 23/8 /2022

To

The Principal
Virmani Public School,
Roop Nagar, Delhi-110007.

Sub: Regarding issuance of fire safety certificate in r/o Virmani Public School, Roop Nagar, Delhi-110007.

Sir,

Please refer to your letter no. 292-VPS/2022-23 dated 21.07.2022 and received in this office vide outdoor dairy no.3782 dated 26.07.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 04.08.2022 to verify the fire safety measures issued vide Director of Education Circular dated 17.01.2005 and observed that as per earlier Fire Safety Certificate issued by this department letter of even no.1675 dated 22.06.2007 the building was comprised of ground & first floor only. At the time of inspection Smt. Rekha Sharma (Principal) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 Fire extinguisher provided but not functional.
- 2 Hose reel hose provided but not functional and damaged condition.
- 3 Terrace level fire fighting pump capacity of 225lpm provided damaged condition. Against the requirement of 450lpm.
- 4 Terrace level fire water tank capacity of 2,000ltrs provided against the requirement of 3,000ltr.
- 5 Exit signage found removed at strategic locations in the school building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully


(Dharampal Bhardwaj)

Dy. Chief Fire Officer

Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.