

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/2022/SZ/ 2108  
To

Dated: 18/08/2022

Sh. Anurag,  
ED/PRVNL/NDLS,  
Residential Housing Flat, Type VI, RVNL,  
(Railway Vikas Nigam Limited)  
Moti Bagh, Near Leela Hotel, New Delhi.

Sub: Regarding issuance of FSC in r/o Community Center, Type V, For RVNL (Railway Vikas Nigam, Ltd) Moti Bagh, Near Leela Hotel, New Delhi.


Sir,

This has reference to your letter No- 2010/RVNL/Type-V/Flats Elect dated 21/07/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 10.08.2022 in the presence of Mr. Thomas to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The clear cut exit door width of community facility building is less than of 1.50 mtr.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully



(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Chief Architect, New Delhi Municipal Council, Department of Architecture & Environs, Palika Kendra, New Delhi.