

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2022/SZ/ 511

Dated: 26/08/2022

To,

The Principal,
Govt. Boys Sr. Secondary School,
Baprola, New Delhi-110043.

Sub: - Regarding grant of NOC from fire safety point of view in r/o Govt. Boys Sr. Secondary School, Baprola, New Delhi-110043.

Sir,

This has reference to your letter no. Nil dated 04/07/2022 on the subject captioned above. In this connection, it is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 09/08/2022 in the presence of Sh. K.C.Meena (Principal) to verify the compliance of shortcoming already communicated by this department vide letter no.F6/DFS/MS/School/2021/SZ/417dated 16/08/2021 & F6/DFS/MS/School/2021/SZ/487dated 13/09/2021 and observed that shortcomings are still not rectified. The management will be held responsible for any untoward incident for the period if compliance is not made.

Yours faithfully



(Sunil Chawdhary)

Dy.Chief Fire Officer



Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.
(with a request to take further action as school does not have fire NOC)

C62

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2021/SZ/ 487

Dated: 13/09/2021

To,


The Principal,
Govt. Boys Sr. Secondary School,
Baprola, New Delhi-110043.

Sub: - Regarding grant of NOC from fire safety point of view in r/o Govt. Boys Sr. Secondary School, Baprola, New Delhi-110043.

Sir,

This has reference to your letter no. GBSSS/BAP/2021-22/168 dated 19/08/2021 on the subject captioned above. In this connection, it is to inform you that the above mentioned school premises was inspected by the officer concerned of this department on 06/09/2021 in the presence of Sh. K.C. Meena (Principal) to verify the compliance of shortcoming already communicated by this department vide letter no.F6/DFS/MS/School/2021/SZ/417 dated 16/08/2021 and observed that shortcomings are still not rectified. The management will be held responsible for any untoward incident for the period if compliance is not made.

Yours faithfully



(Sunil Chawdhary)
Dy.Chief Fire Officer



Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.
(with a request to take further action as school does not have fire NOC)

253

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/2021/SZ/ 417

Dated: 16/08/2021

To,

The Principal,
Govt. Boys Sr. Secondary School,
Baprola, New Delhi-110043.

Sub: - Regarding grant of NOC from fire safety point of view in r/o Govt. Boys Sr. Secondary School, Baprola, New Delhi-110043.


Sir,

Please refer to your letter no. NIL Dated -23/07/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above-mentioned school building from fire safety point of view. During the course of inspection, the following points / shortcomings were noticed:

1. Fire Pump having 450 lpm provided but not functional in APJ Abdul Kalam block & Radha Krishan block.
2. Exits signage's are not provided.
3. Passage lead to new block is blocked by parking shed.

In view of above, the school building cannot be considered for grant of fire safety certificate at this stage .Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully



(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

9cp

Copy to:-

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi-110054.