

(2)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F6/DFS/MS/2022/School/ 572

Dated 29/8/2022

To

The Principal
Guru Harkrishan Public School,
Dhakka Dhirpur, Delhi-110009.

Sub: - Regarding issuance of fire safety certificate in r/o Guru Harkrishan Public School located at Dhakka Dhirpur, Delhi-110009.


Sir,

This has reference to your letter no. GHPS/DD/22-23/56 dated 04.08.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 17.08.2022 to verify the fire safety measures installed in the building as per NBC- Part-4/ Director of Education Circular dated 01.03.2011. During the course of inspection it was observed that the school premise is comprised of Ground plus 02 upper floors only. At the time of inspection Sh. Nishan Singh (Care Taker) was also present at the site and the observations made are as under:-

1. Fire extinguisher provided but not functional.
2. Hose reel hose provided but not functional and some nozzles found damaged.
3. Terrace level fire pump capacity of 450lpm provided but not functional and auto system not functional at the time of inspection.
4. Exit signage found missing at some places at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-23414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.