

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/GH/2022/ 691

Dated 22/8 /2022

To

The Joint Commissioner of Police,
Lic Branch, 1st Floor, Police Station
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Hotel Kings, RZA-97A, Street No 4, Mahipalpur New Delhi 110037.

Sir,

This has reference to MHA Portal ID 2022040405441 dated 28/05/2022 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10/08/2022 in the presence of Ms. Neha (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 There is one staircases having width of 1.25 mtr respectively against the required two staircase having width of 1.50 mtr each.
- 2 Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
- 3 Ventilation system not provided as per clause 7.31 of UBBL 2016.
- 4 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
- 5 The Internal Hydrant not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

Copy to:

1. M/s Hotel Kings, RZA-97A, Street No 4, Mahipalpur New Delhi 110037.