

C-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/GH/SZ/2022/ 697

DATED: 23 08 /2022

To,

The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: Issuance of Fire Safety Certificate in r/o M/s Jaminis Landmark Located at Plot No. 86, Block B, Pocket-10, Sector - 13, Dwarka, New Delhi - 110078.

Sir,

This is in reference to MHA application No. 2022071314588 dated 14/07/2022 on the subject cited above. In this connection it is submitted that the above said premise has been inspected by the officers concerned of this department on 08/08/2022 in the presence of Sh. Anil Sharma.

During the course of inspection followings shortcoming have been observed:-

1. Fire check door found not provided.
2. Smoke exhaust system found not provided in basement & upper floors.
3. Hose Reels & Hydrant Systems at each floor found nonfunctional.
4. Automatic fire detection and alarming system found not provided in basement.
5. CO detectors are found not provided.
6. MOEFA found nonfunctional.
7. PA system found not provided.
8. Two terrace fire pumps of 450 lpm each found not provided.
9. Overhead tank of capacity 10,000 ltr exclusively for firefighting found not provided.
10. Exit Signage found not provided.
11. Lift Signage found not provided.
12. Lift lobby found not provided in basement.
13. Passage to stairs at upper ground floor found blocked by glass door & wooden planks.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Anil Garg)
(Director)

Delhi Fire Service

Copy to:- The Manger, M/s Jaminis Landmark Located at Plot No. 86, Block B, Pocket-10, Sector - 13, Dwarka, New Delhi - 110078.