

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 700

Dated: 24/08/2022

To,

Mrs. Anita Mittal,
House No.E-02 Block,
Prashant Vihar,
Rohini, Delhi-85.

Sub: Issue of FSC in r/o M/s Karan Holiday Inn, E-54, Prashant Vihar, Delhi-110085.

Sir,

Kindly reference to online application No.2022051009876 dated 12.05.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **06.07.2022**, in presence of **Sh. Ravinder Antil (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire check doors are not provided as per Clause 7.31 & UBBL-2016.
2. No ventilation found provided in staircase/upper floors.
3. Natural ventilation not provided corridor and upper floor.
4. Co detectors provided but not functional.
5. Manually operated electric fire alarm provided but not functional.
6. Terrace Fire pump with capacity 900 LPM provided but not functional.
7. One room found constructed on terrace.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
[/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours faithfully

(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

o/c
M