



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/NDZ/2022/ 509

Dated:- 26 /08/2022

To

The Head Master,
Lakhi Public School,
Mandawali, Fazalpur, Delhi-92.

Sub: Regarding Renewal of FSC in r/o Lakhi Public School at Mandawali, Fazalpur, Delhi.


Sir,

This has reference to your letter no. LPS/22-23/1807 dated 18/07/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 05/08/2022 in the presence of Mr. Ajay and the following shortcomings were observed :-

1. Alternate staircase found removed from the school building.

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under the intimation to this department for further necessary action in this regard.

Yours faithfully


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

The Dy. Director of Education,
D-Block, Anand Vihar, Delhi.