



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/School/NDZ/2022 / 513

Dated: 29/8/22

To

The Principal,
M. C. Primary Co-Ed School,
Anarkali, Pul Bangash, New Delhi -06.


Sub:- Regarding issuance of Fire Safety Certificate in respect of **M. C. Primary Co-Ed. School, Anarkali, Pul Bangash, Delhi- 06.**

Sir,

This has reference to letter no. 09 dated 27.07.2022 on the subject cited above. In this connection, it is to inform you that the above mentioned school building was visited by the officer concerned of this department on dated 22.08.2022 to verify the shortcoming already communicated by this department vide letter no F6/DFS/MS/2009/3532 dated 24.11.2009 (copy enclosed) and observed that the school building is not approachable to fire units.

Hence, Fire Safety Certificated can not be considered at this stage. You are suggested to rectify the above said shortcoming under the intimation to this department for further course of action. Running school without valid Fire Safety Certificate is at the risk and liability of school management. Concerned authority may take action at their end.

Yours faithfully,


(S. K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

8
26/8

Copy to:-

The Director of Education,
Govt. of Delhi, Old Secretariat, Delhi.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2009/ 3532

Date: 24/1/09

To

The Principal,
M.C.P Co-Edu. School,
Anarkali, Pul Bangash,
New Delhi-110006

Sub: -Regarding issuance of NOC from fire safety point of view in respect of M.C. P Co-Edu. School, Anarkali, Pul Bangash, New Delhi-110006

Sir,

Please refer to letter No Nil dated 01/07/2009 on the subject cited above. In this connection the premises was visited by the officer of this department and observed that the school is run on Ground floor building and is built on approx 150 sq yards area with 06 rooms and 140 students and **is not approachable to fire units.**

The fire safety arrangements such as few fire extinguishers and sand buckets were seen provided.

The premise is not meeting the requirements of Director of Education letter No. 262-362 dated 17/01/05. (Copy enclosed).

In view of above NOC from fire and safety point of view is not recommended at this stage.

Yours faithfully

Chief Fire Officer
Delhi Fire Service

Copy to: -

Director of Education,
Old Secretariat, Delhi.