

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/Institute/2022/SZ /46

Dated: 30/8/22

To,

The Director,  
R.C. Institute of Technology,  
Gopal Nagar, Najafgarh, New Delhi-110043

**Sub: -** Regarding issuance of Fire Safety Certificate in r/o R.C. Institute of Technology, Gopal Nagar, Najafgarh, New Delhi-110043.


Sir,

This has reference to your Letter No. RCIT/ADMIN/2022/4043 dated 18/07/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the institutional on 08/08/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Dr. Jyotsna Sinha (Director) was present and it was observed that the institutional building is comprised of basement, ground plus three upper floors and have following shortcomings.

1. Hose reel system is provided but not functional.
2. Automatic sprinkler system is provided but not functional.
3. Fire pump having 450 LPM capacity (02 no.'s) provided but not functional.
4. Exit signs are not sufficient.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours Faithfully,



(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER