

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/EH/NDZ/2022/ 542

Dated: 26/08/2022

To,

The Manager,
M/s Sunshine Tea House Pvt. Ltd. (Chaayos),
F-14-15, Mezzanine floor,
Connaught Place, New Delhi.

Sub: Regarding grant of FSC in r/o M/S Sunshine Tea House Pvt. Ltd. (Chaayos) at F-14-15,
Mezzanine floor, Connaught Place New Delhi.

Sir,

This has reference to your online ID no. 2022072014897 dated 24.07.2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned department on 16/08/2022 in the presence of manager and the following shortcomings were observed:-

1. Alternate staircase of 1.25 meter found blocked.
2. The fire check door is not provided at staircase.
3. The building plan as uploaded on the portal does not have signature of the owner /occupier on the plans. Further, the height of building is mentioned 15 meters, same may be clarified whether this is correct or not.

Hence, Fire Safety Certificate can not be renewed at this stage.

Yours faithfully


(S.K.Dua)
Dy. Chief Fire Officer
Delhi Fire Service
✓

Copy to :-

1. The Jt. Commissioner (lic.) Ist floor , defense colony, Police Station , New Delhi ,