

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/CGHS/SZ/2022/ 2206,

DATED: 31/08/2022

To,

Authorized Signatory,
The Neelachal CGHS,
Plot No. 3, Sector – 04,
Dwarka, New Delhi – 110075.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o The Neelachal CGHS Located at Plot No. 3, Sector – 04, Dwarka, New Delhi – 110075.

Sir,

This is in reference to your Email dated-02/08/2022 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 18/08/2022 in presence of Sh. Chetan (Plumber) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six m wide internal road around the building found not provided.
2. Staircases must be kept free from any obstruction & must not be locked at terrace. The passage at terrace between the two blocks must be clear from any obstruction.
3. Two ABC type fire extinguisher of 4 kg capacity at each floor found not provided..

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service

Copy to:-1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.