



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/CGHS/SZ/2022/ 2197

DATED: 31/08/2022

To,

Sh. Inder mohan Bajaj (Secretary),
The New Arohi CGHS Ltd.
Plot No - 13, Sector - 12, Dwarka,
New Delhi - 110078.

Subject: - Renewal of Fire Safety Certificate in r/o The New Arohi CGHS Ltd. Located at Plot No - 13, Sector - 12, Dwarka, New Delhi - 110078.

Sir,

This is in reference to your letter no. NACGH/13/2022-23 Dated-13/07/2022 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 05/08/2022 in presence of Sh. Inder mohan Bajaj (Secretary) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Trimming of trees near internal road must be done on regular interval.
2. Only one fire extinguisher of ABC type 4 kg capacity found provided against required two extinguishers at each floor.
3. Terrace Pumps found nonfunctional in auto mode.
4. During the visit one hydrant was operated heavy leakage was observed. All the hoses / hose fittings must be IS marked.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)
(Director)

Delhi Fire Service

Copy to:-1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.