

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2022/SZ/ 732
To

Dated: 02.10.2022

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s Aashraye Guest House at Plot No-10/5, Nehru Enclave, Kalkaji Extn, New Delhi -110019


Sir,

This is in reference with **MHA Portal ID 2022051009872 dated 27-07-2022** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 07.06.2022 in the presence of Mr. Rahul Kumar of the Guest House. During the inspection, it was observed that the Guest House is running Ground plus Three Upper Floors. The shortcomings observed are as below:

1. Fire check doors not provided at GF of the building as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
4. The fire fighting tank is also being used for domestic purposes.
5. Kitchen at terrace not acceptable as per clause 7.31 of UBBL. 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE



Copy to:-

1. M/s Aashraye Guest House at Plot No-10/5, Nehru Enclave, Kalkaji Extn, New Delhi - 110019