

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2022/EH/550

DATED: 02/09/2022

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o M/s CCB Café Located at shop no 116 to 120, first floor City Centre Mall, Plot no – 5, Sector – 12, Dwarka New Delhi.

Sir,

This is in reference to MHA application No. 2022070413992 dated 05/07/2022 the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officer concerned of this department on 16/08/2022 in the presence of Sh. Dharmender Singh (Manager).

During the course of inspection followings shortcomings are observed:-

1. Three ABC type fire extinguishers of 5 kg capacity found not provided.
2. One exit found blocked.
3. Loose wirings are noticed in the restaurant.
4. Restaurant activities are noticed in the balcony.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

The Manager M/s CCB Café Located at shop no 116 to 120, first floor City Centre Mall, Plot no – 5, Sector – 12, Dwarka New Delhi.