

ra
e-52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS /WZ/2022/ *EH/518*

Dated: *08/08/2022*

To,

Mr. Dilip Thakur,
House No.C-506, Gali No-11 Majlis Park,
Adarsh Nagar,
Delhi-110033.

Sub: Issue of FSC in r/o M/s Green Vatika Hospitality LLP, Shop No.12, situated at 1st floor, DDA Gole Market, CSC-5, Sector-9, Rohini, Delhi-85.

Sir,

Kindly reference to online application No.2022042007736 dated 21.04.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **04.07.2022**, in presence of **Mr. Dilip Thakur** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Interior decoration of roof & walls were found provided with artificial flowers of plastic material.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht
tp://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwa)
Dy.Chief Fire Officer
Tel:-01123414250

oe
me