

C-18

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No. F6/DFS/MS/School/2022/ 518

Dated: 5/9/2022

To

School In charge /HOS,  
Delhi MC Primary School,  
66 Block, New DCM, New Rohtak Road,  
Karol Bagh, New Delhi -110005.

**Sub: Regarding issuance of FSC in r/o Delhi MC Primary School at 66 Block, New DCM, New Rohtak Road Karol Bagh, New Delhi -110005.**

Sir,

This has reference to your letter no. nil dated 26.07.2022 on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 18.08.2022 in the presence of Smt. Deepti kataria and following shortcomings are observed.

1. Hose reel hose is not provided.
2. Overhead tank of 10,000 liter is not provided.
3. Fire Pump of 450 LPM capacity is not provided.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter inform to this department. Running school without valid Fire Safety Certificate is at the risk and liability of school management concerned authority may take action at their end.

Yours faithfully,

  
(Atul Garg)  
**DIRECTOR**  
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.