

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2022/ 537

Dated: 5/8/2022

To

The Principal,
Delhi MC Primary School,
DCM (Co-Ed), Gaushala Marg, Kishan Ganj,
Karol Bagh, New Delhi -110005.

Sub: Regarding issuance of FSC in r/o Delhi MC Primary School DCM (Co-Ed), Gaushala Marg, Kishan Ganj, Karol Bagh, New Delhi -110005.


Sir,

This has reference to your letter no. nil dated 26.07.2022 on the subject cited above. In this regard, it is to inform you that the site was visited by officer concerned of this department on 18.08.2022 in the presence of Smt. Kamlesh Kumari and following shortcomings were observed.

1. Hose reel hose & hydrant found non functional.
2. Fire Pump found non functional.

In view of above, Fire Safety Certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter inform to this department.

Yours faithfully,


(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.