



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2022/ 530

Dated: 5/09/2022

To

The Principal,  
EDMC Primary School,  
Shakarpur Ext. I, Delhi - 110092.

**Sub: Regarding Fire Safety Certificate in r/o EDMC Primary School located at Shakarpur Ext. I, Delhi - 110092.**

Sir,

This has reference to your letter no. nil dated 11/04/2022 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 22/08/2022 in the presence of Mrs. Karuna Sharma (Principal) and observed that earlier school was **Ground floor only** but now the school building is comprised of **Ground + 02 upper floors**. During the inspection following shortcomings were observed:-

1. Hose reel not provided.
2. Fire pump capacity of 450 LPM not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner /occupier. Statutory authority may taken action as deemed fit at their end please.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

The Director (Education),  
Govt. of NCT, Old Sectt.  
Delhi - 54.

gk  
M