

542

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/WZ/2022/ 547

Dated: 07/09/2022

To,

The Vice Principal,
Govt. Sarvodaya Kanya Vidyalaya,
Ashok Vihar Ph-II,
New Delhi - 110052.


Subject: **Regarding Renewal of Fire safety Certificate in r/o Govt. Sarvodaya Kanya Vidyalaya, (Old Block G+2) located at Ashok Vihar, Ph-II New Delhi – 110052.**

Sir,

Please refer to your Email dated 02/08/2022 on the subject captioned above. In this connection, it is to inform you that the said building/premises was re-inspected by the officer concerned of this department on 25/08/2022 in the presence of Sh. Dinesh Pandey (Estate Manager) and observed that the shortcomings already communicated by this department vide letter no. F6/DFS/MS/WZ/2020/91 dated 07/02/2020 & F6/DFS/MS/School/WZ/2022/357 dated 24/06/2022 is still not complied.


In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire officer
Delhi Fire service

Copy to:

1. Directorate of Education, Old secretariat, Delhi – 110054.


02/9/2022

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-38

No. F6/DFS/MS/SCHOOL/WZ/2022/357

Dated: 24/06/2022

To

The Vice Principal/HOS,
Govt. Sarvodaya Kanya Vidyalaya,
Ashok Vihar Ph-II,
New Delhi-110052.

Subject: - Regarding renewal of Fire Safety Certificate in r/o Govt. Sarvodaya Kanya Vidyalaya, (Old Block G+2) Located at Ashok Vihar, Ph-II, New Delhi-110052.

Sir,

Please refer to your letter no. SKV/AV/Ph.II/2022-23/251 dated 25/05/2022 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 15/06/2022 in presence of Sh. Dinesh Pandey (Estate Manager) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/WZ/2020/91 dated 07/02/2020.


The Following Shortcomings Status is:-

S. no.	Shortcomings	Status
1.	Hose reel Hose are found damage	Not Rectified
2.	Fire pump of 450 lpm with 40m head found not functional it must be functional in auto mode.	Not Rectified
3.	Overhead Water tank capacity of 10,000 ltr capacity found removed.	Rectified
4.	Exit sinages found removed.	Rectified

In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone


28/6/2022

1/2 JFF
21/6/2022

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.