

C 9

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/2022/ 543

Dated 06/09/2022

To

The Principal
M.C. Primary School,
8021, Kharia Mohalla, Delhi-110007.

Sub: Regarding issuance of fire safety certificate in r/o M.C. Primary School located at 8021, Kharia Mohalla, Delhi-110007.

Sir,

Please refer to your letter no. Nil and received in this office vide outdoor dairy no.3913 dated 29.07.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 30.08.2022. At the time of inspection Sh. Kailash Chand (Principal) was also present at site to verify the fire safety measures issued Director of Education Circular dated 01.03.2011 and observed that the building was comprised of ground & first floor only. During the course of inspection observations/ shortcomings made are as under:-

- 1 There is only one staircase provided of 1.35m against the required width of 1.50m. And one more staircase also required width of 75cm.
- 2 The class room door width is provided 95cm against the requirement of 01m.
- 3 Exit signage not provided at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully

(Atul Garg)
Director

Ph: 011-23414000

qc p

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.