



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/School/WZ/ 2022 / 524

Dated 5/9/22

To,

The Incharge,
Nigam Pratibha Balika Vidyalaya
No.1, Ramesh Nagar
New Delhi - 110026.

Sub: - Inspection report in respect of Nigam Pratibha Balika Vidyalaya No.1 Located at Ramesh, Nagar, New Delhi-110015. (School ID- 1556154)

Sir,

With reference to outdoor diary no. 4047 dated 03/08/2022 on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 16/08/2022 in the presence of Ms. Chander (Incharge) to see the functioning of the fire safety equipments provided in the building.


During inspection, it has been observed that the said school is comprised of G + 01 upper floors, was issued FSC vide letter No. F.6/DFS/MS/SCHOOL/WZ/2019/1355 dated 28/06/2019. Fire safety arrangements such as, Fire Extinguishers, etc. are provided in the building.

However, following shortcomings were observed: -

1. Width of Main Gate is provided 310cm against requirement is 4.5mts.


In view of above shortcomings, the application for Renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Directorate of Education Old Secretariat Delhi - 110054.


25/8/2022