

C 36

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2022/EH/547

DATED: 02/09/2022

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire Safety Certificate in r/o M/s punter house cafe reloaded (A unit of crossroad Pvt. Ltd.) Located at shop no 102 - 106, first floor City Centre Mall, Plot no – 5, Sector – 12, Dwarka New Delhi.

Sir,

This is in reference to MHA application No. 2022072415116, dated 03/08/2022 & 2022081316144 dated 16/08/2022 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officers concerned of this department on 25/08/2022 in the presence of Sh. Sachin (Manager).

During the course of inspection followings shortcoming are observed:-

1. One exit found blocked.
2. Detectors are found nonfunctional.
3. Restaurant activities are noticed in the balcony.

In view of the above, fire safety certificate cannot be renewed. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Manager M/s punter house cafe reloaded (A unit of crossroad Pvt. Ltd.), shop no 102 - 106, first floor City Centre Mall, Plot no – 5, Sector – 12, Dwarka New Delhi.