

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F. 6./DFS/MS / BP / 2022 / *School/386*

Dated: *05/09/2022*

To,
The Executive Engineer (Bldg.) HQ
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road
New Delhi 110002

Subject: Approval of building plans from fire safety point of view in r/o addn./altn. in existing educational building Shem-Rock Gyan Vatika School at Sector-B, Pocket-1, Vasant Kunj, New Delhi.

Sir,
Please refer your ID No. 10106419 dated 29.08.2022 on the above cited subject. In this connection, this is to inform you that the matter is examined and observed that there is a proposal of addition of 1st floor in the existing school building (Shem-Rock Gyan Vatika School) comprised of Ground floor only located at Sector-B, Pocket-1, Vasant Kunj, New Delhi, for which the FSC was issued vide letter No. F.6/DFS/MS/School/2022/SZ/135 dated 09.02.2022 (copy enclosed). The covered area at existing ground floor and proposed 1st floor is 263.95 sqm each. The height of the proposed building after addition of 1st floor shall be 7.35 m.

This department has no objection for the said addition/ alteration in the building subject to compliance of following conditions:

1. The fire and life safety arrangements such as fire extinguishers, hose reel, Exit Signages, overhead tank of 10,000 liters capacity, terrace pump of 450 LPM capacity etc. shall be provided in the building.
2. Every room with a capacity of over 45 persons shall have 02 exit doors of 1.2 m width.

Further, It shall also be ensured that provisions of all requisite fire and life safety measures stipulated in National Building Code of India/UBBL-2016 shall be complied in letter and spirit before the occupancy of the proposed building under intimation to this department. Any subdivision of the floors and change of occupancy shall only be done with the prior approval of this department. Open set back area is not checked as it shall be checked by concerned building sanctioning authority. It may also be noted that the aforesaid clearance is not a fire safety certificate from Delhi Fire Service.

Yours faithfully


(Atul Garg)
Director

Ph. 011-23414000

