

619

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No: F.6/DFS/MS/School/2022/SZ/ 531

Dated: 5/9/22

To,

The Principal,
Surindra Public School, Block-A-1/1,
Mohan Garden, New Delhi-59.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. Surindra Public School, Block-A-1/1,
Mohan Garden, New Delhi-59.

Sir,

This has reference to your letter No. S/P/S/14/2022/7/02 dated 14/07/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 22/08/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Veena Sharma (Principal) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. One of the staircases shall be provided 1.5 m wide upto terrace
2. First aid hose reels are not provided.
3. Fire pump having 450 lpm output 40 m head not provided.
4. Over head water tank having 10,000 liters not provided.
5. Exits signages are not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.