



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/Club/NDZ/2022/ 2249

Dated:- 05/09/2022

To

The Executive Engineer (Bldg.), MCD
Dr. S.P. Mukherjee Civic Center,
JLN Marg, New Delhi-110002.

Sub:- Joint Site Inspection Report for Completion Cum Occupancy Certificate in r/o M/s The Great Getsby Club of India, I.P Extension, Mandawali Fazalpur Delhi-110092.

Sir,

This has reference to MCD portal **online I.D- 10104846 dated 01.09.2022** on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officers concerned of this department on 01/09/2022 in the presence of MCD officers i.e. Sh. Pushpender Kr., EE(B), Sh. K.P. Yadav AE(B) & Sh. S.C. Meena JE(C) and observed that building comprised of 02 basement + Ground + 04 upper floors

Following shortcomings were observed during the inspection:-

1. 06 meter access encroached in two side, one side Covered for dinning & back side canopies are erected.
2. Ventilation system neither integrated nor functional.
3. Fire Check door found removed at some locations.
4. Lift lobby not provided.
5. Shafts are not sealed.
6. Exit width in Bar/Restaurant/Halls & other areas are not provided as per approved plans.
7. Exit signage found removed at some places.
8. Staircases are not segregated at ground floor.
9. Wooden paneling in staircase to be removed.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service



Copy to:-

The Authorised Signatory,
M/s The Great Getsby Club of India,
I.P Extension, Mandawali Fazalpur,
Delhi-110092.