

C-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F/DFS/MS/School/WZ/2022/ 48

Dated: 6/9/22

To,

The Principal,
V.D (Varun Dhaka) Institute of Technology,
Khasra No.72/9, 72/8, Kirshan Vihar,
Near Sultanpuri Bus Terminal,
Delhi.110086.

Sub: Issue of FSC in r/o V.D (Varun Dhaka) Institute of Technology, Khasra No.72/9, 72/8, Kirshan Vihar, Near Sultanpuri Bus Terminal, Delhi.110086.


Sir,

This is in reference to your letter No. VDIT/ADM/2022/008 dated 15.07.2022 received through outdoor diary no. 3438 dated 15.07.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **25.08.2022**, in presence of **Dr. S. K. Mishra (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 5000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs.
2. Terrace fire pump is not connected with water tank.
3. Terrace Fire pump with capacity 900LPM provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

ote
ny