

CL

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No: F.6/DFS/MS/School/2022/SZ/ 534

Dated: 5/9/22

To,

The Principal,
Vijay Model School, D-736,
Shiva Enclave, Vikas Nagar, Uttam Nagar, New Delhi-110059.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. Vijay Model School, D-736,
Shiva Enclave, Vikas Nagar, Uttam Nagar, New Delhi-110059

Sir,

This has reference to your Letter No. Nil dated 15/07/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 11/08/2022 to verify the fire safety arrangements in accordance with the Circular. At the time of inspection Mrs. Deepa Mathela (Teacher) was present and it was observed that the school building is comprised of ground floor only and have following shortcomings.

1. Fire Extinguishers ABC/CO2 type not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Sunil chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054, (with a request to take further action as school does not have fire NOC)