

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/SZ/ 538  
To

Dated: 5/9/2022

The Principal,  
The Mother's International School located at  
Sri Aurobindo Marg, New Delhi-110016.

Sub: Regarding issuance of FSC in r/o The Mother's International School located at Sri Aurobindo Marg, New Delhi-110016.


Sir,

This has reference with your letter no MIS/A17-3/2004 dated 20/07/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 23.08.2022 in the presence of Mr. IBO (Adm Officer) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Ventilation system not functional in the basement.
2. Pumps are not on auto mode.
3. Manual call points are not working.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/Management of School. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054