

C 25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No F6/DFS/MS/School/2022/ 548

Dated: 08/09/2022

To

The Principal,  
Delhi United Christian Senior Sec. School,  
17, Raj Niwas Marg, Delhi- 110054.

**Sub:** - Regarding issuance of "**Fire Safety Certificate**" from fire safety point of view in r/o **Delhi United Christian Senior Sec. School** located at **17, Raj Niwas Marg, Delhi- 54**.

Sir,

This has reference to your letter no. nil dated 06.08.2022 on the subject cited above. In this connection it is to inform you that officer concerned of this department inspected the school/ premises on 27.08.2022 to verify the fire safety arrangements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education. At the time of inspection Ms. Monika Alexander (Vice Principal), was present and it was observed that the school building is comprised of ground plus one upper floor and have been partially complied the shortcomings issued vide letter no. F.6/DFS/MS/School/NDZ/2022/436 dated 27.07.2022 except following which still exists:-

1. Domestic LPG Cylinder cannot be used in science lab for any purpose.

In view of above shortcoming, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(S.K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service o/c

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.