



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

Dated:- 30/08/2022

No.F6/DFS/MS/NDZ/Benq./2022/ 156

To

The Dy. Commissioner of Police,  
1<sup>st</sup> floor, PS Defence Colony, New Delhi-100049.

**Sub: Regarding issuance of FSC in r/o Garg Celebration (earlier J.R.P. Vatika Banquet Hall)  
at 1<sup>st</sup> & 2<sup>nd</sup> floor, C-24, 25, Acharya Niketan, Opp. Mayur Vihar-1, Delhi - 110091.**

Sir,

This has reference to your online id no. 2022080415754 dated 04/08/2022 on the subject cited above. In this regard, it is to inform you that the premises has been inspected by the officer concerned of this department on dated 12/08/2022 in the presence of Mr. Yogesh Garg & Mr. Ahmed and no progress was seen on the shortcomings communicated by this department vide letter no. F6/DFS/MS/NDZ/BNQT./2022/56 dated 25/04/2022 (photo copy enclosed).

Hence, the Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under the intimation to this department for further necessary action in this regard.

Yours faithfully

  
(S.K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

Encl: as above

Copy to:-

Mr. Rakesh Garg,  
Garg Celebration (earlier J.R.P. Vatika Banquet Hall),  
1<sup>st</sup> & 2<sup>nd</sup> floor, C-24, 25, Acharya Niketan, Opp. Mayur Vihar-1, Delhi - 110091.

16th I

op

x - 1

4/23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/ND2/2022/56

Dated: 25/4/2022

To,

Authorized Signatory,  
Garg Celebration (earlier J.R.P. Vatika Banquet Hall),  
1<sup>st</sup> & 2<sup>nd</sup> Floor, C-24, 25, Acharya Niketan, Opp. Mayur Vihar-1, Delhi-91

**Sub:- Fire Safety Certificate in r/o Garg Celebration (earlier J.R.P. Vatika Banquet Hall) at 1<sup>st</sup> & 2<sup>nd</sup> Floor, C-24, 25, Acharya Niketan, Opp. Mayur Vihar-1, Delhi-91.**

Sir,

Please refer to your letter received through MHA portal application No. 2022040605887 dated 06/04/2022 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 18/04/2022 in the presence of Sh. Rakesh Garg and following shortcomings were observed during the time of inspection:-

1. Fire check doors found removed.
2. Door Size of 1st Floor are 1.50m & 1.30m and 2nd Floor are 1.80m & 1.30m against requirements of 2m width at each floor.
3. First Aid Hose Reel & Internal Hydrant provided but found nonfunctional.
4. A Fire pump of 450 LPM Provided but found nonfunctional.
5. 2<sup>nd</sup> staircase on ground floor is blocked which should be opened. Also there is meter board and electrical panel board under this staircase / Fire Exit on ground floor which should be replaced.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected.

The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR.

Copy to:-

Joint Commissioner of Police, 1st Floor, PS Defence Colony, New Delhi 110049.  
w.r.t MHA portal ID NO. 2022040605887 dated 06/04/2022.

ok