

C42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2022/SZ/ 743  
To

Dated: 07.10.2022

The Joint Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, P.S Defence Colony,  
New Delhi 110049

Sub: Regarding issuance of NOC in r/o Hotel M G Hospitality, (H Carlton), KH No.-538,  
Village-Chandan Hulia, Chattarpur Mandir Road, New Delhi-110074

Sir,

This has reference to your MHA Portal ID 2022071814834 dated 02/08/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20.08.2022 in the presence of Mr. Aman (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016.
3. First aid hose reel provided but not functional.
4. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016
5. The MOEFA system is provided but not functional.
6. Fire fighting pumps is provided but not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. Hotel M G Hospitality, (H Carlton), KH No.-538, Village-Chandan Hulia, Chattarpur Mandir Road, New Delhi-110074

