

C18

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No.16/DFS/MS/ School/WZ/2022 | 545

Dated : 07/09/2022

To,

The Principal,
M.C. Pry. Co-ed Primary School,
Raj Park Sultanpuri,
Delhi- 110086.

Sub:- Issuance of Fire Safety Certificate in r/o M. C. Pry. Co-ed Primary School, Located at Raj Park, Sultanpuri, Delhi- 110086.

Sir,

This is in reference to your letter No. nil dated 08.08.2022 received through outdoor diary no. 4175 dated 08.08.2022 on the subject cited above. In this connection it is to inform you that the shortcoming already issued by this department letter of even No. 1169 dated 30.05.2014 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 30.05.2014 for further consideration in this matter.

Yours Faithfully


(Dhrampai Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

OK
9/9

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

NO. F-6/DFS/MS/2014/ *school/1168*

Date: *30/05* /2014

To

The Principal,
M. C Primary Girls/Boys School,
Raj Park, S.P Road,
Sultan Puri, Delhi -110086.

Sub: Regarding fire safety certificate in respect of M. C Primary Girls/Boys School, Raj Park, S.P Road, Sultan Puri, Delhi -110086.

Sir,

Please refer to your letter No RPI/RZ/124 Dated 15/02/2014 on the subject cited above. In this connection it is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department along with school authority on 24/04/2014 from fire safety point of view and following shortcomings were observed.

1. Only 03 No's of ABC type fire extinguisher are provided against the required 08 no's of CO₂/DCP type 2.5 kg cap. each.
2. Hose reel not provided. Hose reel required to be provided at each floor.
3. Terrace pump of 450 LPM capacity not provided.
4. Over head water storage tank of cap. of 10000 not provided.

Keeping in view of the above fire safety certificate cannot be considered at this stage.

Yours faithfully

28/5
VIPIN KENTAL
Dy Chief Fire Officer
Delhi Fire Service
Ph: 011-23846352
dfowz.dlfire@nic.in

Copy to:

1. The Addl. Director of Education, North MCD, Civic Centre New Delhi.