

C 15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.F6/DFS/MS/School/2022/ 549

Dated 08/09/2022

To

The Principal
Nigam Utkrisht Vidyalaya,
Padam Nagar, Delhi-110007.

Sub:- Regarding issuance of fire safety certificate in r/o Nigam Utkrisht Vidyalaya, located at Padam Nagar, (Jai Rani Bagh), Delhi-110007.


Sir,

Please refer to your letter no. Nil dated 27.07.2022 and received in this office vide outdoor dairy no.3926 dated 29.07.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 30.08.2022 to verify the fire safety measures issued vide Director of Education/NBC Pat-IV and observed that the school premise is comprised of 02 blocks interconnected, ground & two upper floors each only. At the time of inspection Sh. Satpal, Principal was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 The main gate width of 3.60m provided against the requirements of 4.50m each.
- 2 Hose reel hose provided but damaged/leakage condition.
- 3 Terrace level fire fighting pump capacity of 450lpm provided but not an auto mode.
- 4 Exit signage not provided at strategic locations in the school building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully


(Anil Garg)
Director

Ph: 011-23414000

01/09/22

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt, Delhi - 110054.