



C-25 7/11/22
Atul Garg

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/2022/NDZ/ 550

Dated: 08/09/2022

To

The Manager,
Pooja Model Public School,
87/6, Shiv Mandir, Gali No.-6, Maujpur, Delhi-110053.

Sub.:- Regarding Issuance Fire Safety Certificate in r/o Pooja Model Public School, 87/6, Shiv Mandir, Gali No.-6, Maujpur, Delhi-110053.

Sir,

With reference to your letter No. PMPS/2022/March/16-001 dated 16/03/2022 on the subject cited above, in this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 27/08/2022 in presence of Sh. Gaurav Rawal (Chairman). The following points / shortcomings were noticed in the building which is now comprised of ground plus two upper floors.

1. First-Aid hose reel provided but nonfunctional.
2. A Fire pump having capacity of 220 LPM is provided against requirement of 450 LPM.
3. Over head tank of 2500 ltr is provided against requirement of 10,000 liters.
4. Exit Signages not provided.

In view of above, the building can not be considered for issuance of Fire Safety Certificated at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully,


(ATUL GARG)
DIRECTOR.

Copy to:-

The Director of Education,
Directorate of Education, Lucknow road,
Delhi-110054.

ok 