

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/CGHS/2022/ 2274

Dated: 07/09/2022

To,

The President <palmsdwarka@gmail.com>  
Subh Lakshmi CGHS Ltd.  
Plot No-13 B, Sector-06, Dwarka,  
New Delhi- 110075

Subject: Renewal of Fire Safety Certificate in r/o Subh Lakshmi CGHS Ltd. Plot No-13 B, Sector-06, Dwarka New Delhi- 110075.

Sir,

This is in reference to your Email, dated-06/08/2022 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 24/08/2022 in presence of Sh. Arvind (Society Manager)

During course of inspection the following shortcomings were observed.

1. Only one ABC type fire extinguisher of 5kg capacity is found provided at each floor against required two fire extinguishers
2. During the inspection one hydrant was operated heavy leakage was noticed from hose fittings. All the hoses, hose fittings, Branches & couplings must be IS marked.
3. The pumps found not functional in auto mode.
4. Exit signage found removed at some places.
5. Communication system in the lift car found nonfunctional.
6. Duly fill Form J & K are not provided.

You are requested to comply the abovementioned shortcomings under intimation with this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to; - The Joint Director, DDA, Vikas Sadan, INA, New Delhi.