



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2022/SZ/ 753
To

Dated: 08.09.2022

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s "Arien International" at E-189, Kalkaji, New Delhi-19

Sir,

This has reference with **MHA Portal ID 2022060311996 dated 28-07-2019** on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department in the presence of Mr. D S Rawat (Manager) on 23.08.2022. The shortcomings observed are as below:

1. Fire check doors not provided of the building as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
4. Fire fighting pumps are not auto mode.
5. Kitchen at terrace not acceptable as per clause 7.31 of UBBL. 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. M/s "Arien International" at E-189, Kalkaji, New Delhi-110019