GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2022/Guest House/WZ/ 755   Dated: 08/09/2022

To,

Mr. Shyam Lal,
House No.365, Gali No.11,
Nathu Coloney Nathu Pura,
Delhi-110084.

Sub: Issue of FSC in r/o Hotel Rohil Residency, Shop No.53/19 & 43/22, Village Pehladpur Bangar, Delhi-110043.

Sir,

This is in reference to your online application No.2022052010773 dated 21.05.2022 received on the subject cited above. The premise was inspected by the concern nominated authority of this department on 05.08.2022, in presence of **Sh. Shyamlal** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Numbers of rooms & floor plan are not matching with building.
2. Staircase & corridor not ventilated.
3. Detection & alarm system are not provided.
4. Fire check door is not provided.
5. Banquet at ground floor is not segregated with guest house.
6. Terrace Fire pump with capacity 450 LPM provided against the required capacity of 900 LPM.
7. 5000 ltrs Over Head water captive tank provided against the required capacity of 15,000 ltrs.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR
Ph; 011-23414000

1. Hotel Rohil Residency, Shop No.53/19 & 43/22, Village Pehladpur Bangar, Delhi-110043