

C 75

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.F6/DFS/MS/GH/SZ/2022/ 739

Dated: 07/09/2022

To,

The Owner/Occupier,
M/s. Hotel Le Sancy, 7A/47, WEA,
Channa Market, Karol Bagh, New Delhi- 110005.

Sub.:- Regarding renewal of NOC in respect of M/s. Hotel Le Sancy, 7A/47, WEA, Channa Market, Karol Bagh, New Delhi- 110005. from fire safety & means of escape point of view.

Sir,

Please refer to your Online MHA Application Id No. 2022080415756 dated 05.08.2022, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 18.08.2022 in the presence of Sh. Manoj (manager), to check the functionability of fire safety arrangements already provided in the guest house building.

During inspection, it has been observed that the said guest house building comprised of basement, ground plus two upper floors. Fire safety arrangements such as MOEFA, P.A. system, overhead water tank capacity 4,000 lts. etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building :-

1. Fire Check Doors found not provided.
2. Ventilation system found not provided at upper floors level.
3. Carbon Monoxide detector found not provided.

In view of the above, as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019, the FSC issued vide letter no F.6/DFS/MS/GH/SZ/2018/961 dated 09.05.2018 is rejected for renewal of FSC. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to :-

1. The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.