



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F.6/DFS/MS/BNQT/WZ/2022/ 158

Dated: 6/9/22

To

Sh. Jitender Kumar Puri,
M/s. La Mansion Banquet Hall,
C-92, Wazirpur Industrial Area,
New Delhi- 110052.

Sub: - Regarding inspection report in r/o M/s. La Mansion Banquet Hall located at C-92,
Wazirpur Industrial Area, New Delhi- 110052.

Sir,

This is in reference to your online application received through MHA portal vide ID-2022080115628 regarding the subject cited above. In this connection, it is to inform you that the building was inspected by the officer concerned of this department on 22.08.2022 in your presence to check the status of the fire safety arrangements already provided in the banquet hall building.

During the course of inspection, it was observed that the said banquet hall is comprised of basement, mezzanine, ground plus two upper floors. Fire safety arrangements such as fire extinguishers, first aid hose reels, detection & alarming system, MOEFA, sprinkler system, internal hydrants, yard hydrants, fire pumps, underground water tank capacity 1,00,000 lts, overhead water tank capacity 5,000 lts etc. found provided. However, following shortcomings were observed: -

1. Electric fire pump capacity 2280 LPM is provided but not functional.
2. Sprinkler system, first aid hose reels, internal hydrants, yard hydrants are provided but not functional.
3. Overhead water tank capacity 5000 lts is provided against required 10,000 lts.
4. Fire/smoke check doors found removed from staircase & lift lobbies at each floor.
5. Exit signages found removed.
6. Ventilation system in upper floor found removed.

In view of the above shortcomings, the application for renewal of fire safety certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Deputy Health Officer, Keshavpuram Zone, Delhi Municipal Corporation, Keshavpuram, New Delhi.