

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/SZ/2022/ 77

Dated: 09 109 12022

To

The Owner/Occupier,

M/s. Apra Deluxe guest house, 12A/35, WEA, Karol Bagh, New Delhi-110005.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Apra Deluxè guest house. 12A/35, WEA, Karol Bagh, New Delhi-110005.

Sir.

Please refer to your online MHA application Id 2022081016028, dated 12.08.2022, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department, in presence of Sh. Vishawanatha, (Manager) on 31.08.2022 to check the status of the shortcomings already pointed out by this department vide letter No. F6/DFS/MS/GH/SZ/2022/655 dated 05.08.2022. During the course of inspection, it was observed that the shortcomings are not complied.

In view of above, Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further necessary action in this matter.

Yours faithfully

(Sunil Chaudhary)

Dy. Chief Fire Officer (SZ)

Delhi Fire Service

Copy to: -

1. The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.

C43

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.F6/DFS/MS/GH/SZ/2022/ 6 5

Dated: 5/8/22

To.

The Owner/Occupier, M/s. Apra Deluxe guest house, 12A/35, WEA, Karol Bagh, New Delhi-110005.

Sub.:- Regarding renewal of NOC in respect of M/s. Apra Deluxe guest house, 12A/35, WEA. Karol Bagh, New Delhi-110005 from fire safety & means of escape point of view.

Sir.

Please refer to your Online Application No. 20220700814256 dated 09.07.2022, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 22.07.2022 in the presence of Sh. Vishawanath, manager), to check the functionability of fire safety arrangements already provided in the guest house building.

During inspection, it has been observed that the said guest house is comprised of basement, ground plus three upper floors. Fire safety arrangements such as MOEFA, P.A. system, overhead water tank capacity 10,000 lts. etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building:-

- 1. Fire Check Doors found not provided.
- 2. Carbon Monoxide detectors found not provided.
- 3. Terrace fire pump found 900 LPM provided but not functional.

In view of the above, as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019, the FSC issued vide letter no F6/DFS/MS/GH/SZ/2017/1000 dated 11.07.2017 is rejected for renewal of FSC. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yourș-faithfully

(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)

Delhi Fire Service

Copy to :-

1. The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.